


FIRE SAFETY CERTIFICATE

No. 0125191221500114

Dated: 04.05.2023

Certified that the ST. NICHOLAS PUBLIC SCHOOL (name of the building or premises) at MOUZA - AMLAGORA, PLQT-1565, J.L NO - 482, DIST - PASCHIM MEDINIPUR, PIN-721101 (address) comprised of NIL basement(s) and GROUND FLOOR & FIRST FLOOR (upper floors) owned/ occupied by ST. NICHOLAS PUBLIC SCHOOL (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 13/02/2019 (date of inspection) in the presence of KANCHAN PAN (MANAGER) (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes XII (XI/ XII) With effect from 16/09/2023 for a period of 5 (three) year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Mock Fire practice and evacuation drill shall be performed periodically with participation of occupants of building.
 2. The Fire safety audit to be conducted a regular interval and to be recorded in the Fire Prevention manual.
 3. Existing electrical wiring of whole building shall have to be carefully checked for any where or trip in them particularly lines above fans ceiling and ducts.
 4. Periodical flushing of water from the fire fighting pipe line shall be made to maintain the efficient working performance of the above mentioned systems.
- Issued on 16/02/2023 (date of issue) at Medinipur (place) by


 06/05/2023
 Divisional Fire Officer
 Paschim Medinipur Division
 West Bengal Fire & Emergency Services
 Name: BAN KUMAR CHOWDHURY
 Designation: Divisional Fire Officer

*Strike out whichever is not applicable.

Name & Address of Department/ Office: office of the Divisional Fire Officer, Paschim Medinipur Division, West Bengal Fire & Emergency Services.

To

 (Name & Address of the institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

 (reasons to be recorded).
 (Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services
Sepoy Bazar, P.O.:- Medinipur, P.S.:- Kotwali, Pin:- 721101

Memo no.:IND/WB/FES/20192020/69315

Date: 16-02-2023

From:
Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services

To: ST. NICHOLAS PUBLIC SCHOOL
BESIDE GARHBETA COLLEGE, MOUZA - AMLAGORA, PLOT - 1565, JL NO - 482, DIST - PASCHIM MEDINIPUR,
PIN - 721121

Sub: Renewal of Fire Safety Certificate 2nd floor proposed over an existing of G+1 storied only School Building, not extended administrative part the name in style of ST. NICHOLAS PUBLIC SCHOOL under group of Educational at Mouza – Amlagora, Plot No. – 1565, J.L. No. – 482, P.S. – Garbeta, Dist – Paschim Medinipur, Pin – 721121.

This is in reference to your application no. 0125191221500114 dated 29-12-2022 regarding the Renewal of Fire Safety Certificate 2nd floor proposed over an existing of G+1 storied only School Building, not extended administrative part the name in style of ST. NICHOLAS PUBLIC SCHOOL under group of Educational at Mouza – Amlagora, Plot No. – 1565, J.L. No. – 482, P.S. – Garbeta, Dist – Paschim Medinipur, Pin – 721121.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No perking will be allowed on the driveway.
2. Directional sign and escape route shall be displayed prominently.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.

4. The interior finish decoration of building shall be made with low flame spread material confirming I.S. Specification.
 5. The notice of Fire Fighting and Evacuation with "Exit Sign" from the building shall be prepared and displayed at all vulnerable places of the building.
 6. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing
 7. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
 8. First – Aid Fire Fighting system shall be provided as per I.S Specification.
 9. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
 10. If required the old line shall have to be replaced with new line the cables shall always be laid in M.S. conduit pipes continuously bounded to the earth.
 11. Periodical flashing of water from the Hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
 12. The Fire Safety audit to be conducted at a regular interval and to be recorded in the Fire Prevention maintenance register.
 13. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling and ducts.
 14. A Fire control room with close circuit T.V. system will have to be installed which will observe all the floor of the building.
 15. Transformer and Switch Gear room shall be protected with automatic CO2 or D.C.P. Fire extinguisher conforming I.S. Specification.
 16. Renewal of fire safety Certificate are allowed on condition to increase the Fire Pump capacity by 5HP within THREE months from the date of issued of this certificate otherwise this certificate may be treated as rejected.
 17. This Renewal Fire Safety Certificate is valid for three years and has to be renewed every three years from the date of issue of this letter.
 18. Each three years a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all the Life & Fire Safety arrangements and installation of the building.
- N.B: No addition and alteration without prior permission of West Bengal Fire & Emergency Services. Otherwise the Fire Safety certificate will be treated as cancelled.

Signature valid

Digitally Signed
Name: Barn Kumar Choudhury
Date: 16 Feb 2024 16:31:25
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services

Memo No.: IND/WB/FES/20192020/69375